

C E R T I F I C A T E
of Conformity



Registration No.: AK 50498979 0001

Report No.: CN2189OK 001

Holder: JIANGSU GOODWE POWER SUPPLY
TECHNOLOGY CO., LTD.
No.90 Zijin Rd.,
New District, Suzhou
215011 Jiangsu
P.R. China

Product: PV-Inverter
(Grid-connected PV Inverter)

Identification:
Type Designation: GW100K-HT GW110K-HT
GW120K-HT GW136K-HTH
Firmware Version: V1.04.04.01
Serial Number : Engineer Sample
Remark : Refer to test report CN2189OK 001 for
details.

Tested acc. to: CEI 0-16:2019

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.



Date 31.03.2021

Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg



OGGETTO: Dichiarazione di conformità alla normativa CEI 0-16:2019
 "Regola tecnica di riferimento per la connessione di Utenti attivi e passivi alle reti AT ed MT delle imprese distributrici di energia elettrica"

SUBJECT: Declaration of Conformity to CEI 0-16:2019

"Reference technical rules for the connection of active and passive consumers to the HV and MV electrical networks of distribution Company"

Certificate No.: AK 50498979 0001

TIPOLOGIA DI APPARATO A CUI SI RIFERISCE LA DICHIARAZIONE:

TYPE OF APPARATUS WHICH THE DECLARATION IS REFERED TO:

GENERATORI SINCRONI Synchronous generators	GENERATORI ASINCRONI Asynchronous generators	GENERATORI STATICI FV Static generators PV	GENERATORI EOLICI FULL CONVERTER Full Power Wind Generators
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Costruttore
Manufacturer

Jiangsu Goodwe Power Supply Technology Co., Ltd.
NO.90 Zijin Rd., New District, Suzhou 215011 P.R. China

Modello/Tipo
Model/Type

	GW100K-HT	GW110K-HT	GW120K-HT	GW136K-HTH
Potenza Attiva Nominata Nominal Power [kW]	100	110	120	136
Max. Potenza Apparente Maximum Apparent Power [kVA]	110	121	132	150

Firmware release
Firmware

V1.04.04.01

Numero di Fasi
Number of phases
Informazioni sulla batteria
Battery information

Trifase/ Three-phase

N/A

Note
Remarks

Il dispositivo è in grado di limitare la I_{dc} allo 0,5% della corrente nominale.
The device is capable to limit the I_{dc} to 0,5% of the nominal current.

laboratorio di prova
Test laboratory

TÜV Rheinland (Shanghai) Co., Ltd.
Accreditation CNAS no.: L3038

Esaminati I Fascicoli Prove N.: CN2189OK 001 emesso da TÜV Rheinland (Shanghai) S.r.l.
Having assessed the Test Files N. CN2189OK 001 issued by TÜV Rheinland (Shanghai) Co., Ltd.

Si dichiara che i prodotti indicati soddisfano i requisiti della CEI 0-16:2019 "Regola tecnica di riferimento per la connessione di Utenti attivi e passivi alle reti AT ed MT delle imprese distributrici di energia elettrica"
We declare that the products indicated meet the requirements laid down by CEI 0-16:2019 "Reference technical rules for the connection of active and passive consumers to the HV and MV electrical networks of distribution Company"

Validità della
Dichiarazione
Validity of the
Declaration

Questa Dichiarazione è valida per i prodotti indicate, così come descritti nei Fascicoli citati. Nuovi requisiti o emendamenti a requisiti esistenti, così come modifiche al prodotto, possono implicare nuove verifiche e certificazioni.
This Declaration is valid only for the products indicated herein, as described in the Files mentioned. New requirements or amendment to existing ones, or modifications to the product, may imply re-verification and re-certification.

JIANGSU GOODWE POWER SUPPLY
TECHNOLOGY CO., LTD.
Mr. Jiang Tao

Date : 31.03.2021
Our ref. : HCC 01
Your ref.: Jiang Tao

No.90 Zijin Rd.,
New District, Suzhou
215011 Jiangsu
P.R. China

Ref : AK Certificate of Conformity

Type of Equipment : Grid-connected PV Inverter
Model Designation : See Certificate
Certificate No. : AK 50498979 0001
Report No. : CN21890K 001

Dear Mr. Jiang Tao,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body


Weichun Li

CC: JIANGSU GOODWE POWER SUPPLY

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询